


VOLTAGE TEST STATION**H-S10S21-M3RX****VOLTAGE
IF ILLUMINATED****VOLTAGE
TEST POINTS****WARNING**

QUALIFIED PERSONNEL
FOLLOW YOUR FACILITY
SAFETY PROCEDURES
WHEN USING
THIS DEVICE



NOTE:
TEST POINT ASSEMBLY
WITH 102 kΩ IMPEDANCE
ON L1, L2, L3 & GND
AFFECTS VOLTAGE
READINGS $\pm 2\%$

HINGE5.83
[148]**2X 30mm
Pushbutton
Knock-outs**2.76
[70]**GRACE**
PESDs®**800-280-9517**0.26
[6.5]**GRACE**
**ENGINEERED
PRODUCTS, INC****LATCH**PESD® TemplateH-TEMPLATE-M