



APPLICATION

Series GZ Potentiometers are used in control stations, panels and enclosures used in areas made hazardous due to the presence of flammable vapors, gases or combustible dusts.

UL/CSA application details:

Identification:	Class I, Division 1 , Groups B, C, D Class II, Division 1, Groups E, F, G Class III
Certificate:	E12379
Ambient temperature range:	-50°C to +60°C
Thread:	M22x1.5 (Series GZ with -M Suffix) 3/4" x 14 NPSM (Series GZ)
Required threads (Class I)	Six (6) full threads engaged (GZ*-M) Seven (7) full threads engaged (GZ*)
Required threads (Class II and III):	Three (3) full threads engaged (GZ*-M and GZ*)
Ingress protection:	Type 4X
Storage temperature in original packaging	-20°C to +50°C

APPLICABLE STANDARDS

- UL 1203 Standard for Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for use in Hazardous (Classified) Locations
- UL 50 / UL50E Enclosures for Electrical Equipment
- UL 508 Standard for Industrial Control Equipment
- CSA C22.2 No. 25-1966 Enclosures for use in Class II, Groups E, F, G Hazardous Locations
- CSA C22.2 No. 30-M1986 Explosionproof Enclosures for use in Class I Hazardous Locations
- CSA C22.2 No. 94-M91 Special Purpose Enclosures Industrial Products
- CSA C22.2 No. 14-13 Industrial Control Equipment
- EN 60079-0:2012/A11 | IEC 60079-0:2011 6^a Ed. | NBR IEC 60079-0:2013
- EN 60079-1:2014 | IEC 60079-1:2014 7^a Ed. | NBR IEC 60079-1:2016
- EN 60079-31:2014 | IEC 60079-31:2013 2^a Ed. | NBR IEC 60079-31:2014

ELECTRICAL SPECIFICATIONS

POTENTIOMETERS (for mult-turn potentiometer, omit Step 2):

- Remove the hex nut from the threaded bushing.
- Install the indicator plate onto the bushing.
- Screw the operator into the enclosure threaded entry, 3/4"NPSM for (GZ*) or M22x1,5 for (GZ*-M) with a torque of 3 Nm to 6 Nm.
- Adjust indicator plate with regard to position marked on button with potentiometer base inside the enclosure.
- Remove the potentiometer base, install the hex nut on bushing from inside enclosure and tighten with appropriate device, with a torque of 2 Nm.
- Fix the cables/wires in potentiometer terminals through weld.
- Plug the potentiometer base in the knob and fix it with your cage.
- Tighten Allen screws.

STORAGE

Upon receiving the product, the parts must be stored in a covered, clean and dry place so that there is no contact between threads of the products.

INSPECTION AND MAINTENANCE

Inspection and maintenance must be performed in accordance with the applicable codes of practice by an appropriately trained person.

REPAIR

A properly trained person shall perform the repair of equipment in accordance with the manufacturer's instructions and applicable codes of practice. Repair/modification must be performed only with manufacturer original parts and should be limited to the replacement of the following parts:

- Gasket



CERTIFICATION INFORMATION:

IECEx AND ATEX SPECIAL CONDITIONS FOR SAFE USE:

- For flameproof applications, the actuators shall only be installed in Ex d enclosures with maximum internal volume of 35 liters and approved for at least Group IIC according to EN60079-1/IEC 60079-1.
- For flameproof applications, the actuators shall only be installed in Ex d enclosures with maximum internal explosion pressure of 20 bar for Group IIC according to EN60079-1/IEC 60079-1.
- The actuators shall only be used for a service temperature range of -50°C to +60°C.
- For flameproof applications, the actuators shall only be threaded in enclosure walls having a minimum length of 8.0 mm for M22x1,5 thread, and at least five (5) threads engaged for 3/4" NPSM thread, according to table 4, from EN 60079-1/IEC 60079-1. The maximum thickness of the enclosure wall is limited by size (length) of the actuating and signal elements.
- For dustproof applications, the actuators shall only be threaded in enclosure wall having a minimum length of 3,0 mm for M22x1,5 or 3,7 mm for 3/4" NPSM thread, and at least threads engaged according to EN 60079-31/IEC 60079-31. The maximum thickness of the enclosures wall is limited by size (length) of the actuating and signal elements. The elements have to be fixed in the electrical equipment in such a way that rotation and accidental loosening will be prevented.
- The outer molding of the elements has to be tightened according manufacturer's instructions.
- For flameproof applications, the actuators shall only be installed in Ex d enclosures with maximum internal volume of 160 litres and approved for at most Group IIB+H2, according to EN60079-1/IEC 60079-1.
- For flameproof applications, the actuators shall only be installed in Ex d enclosures with maximum internal volume of 35 liters and approved for at least Group IIC, according to EN60079-1/IEC 60079-1.
- The flameproof joints are not intended to be repaired.

IMPORTANT:

Technical information, advice and recommendations contained in these documents is based upon information that Killark believes to be reliable.

All the information and advice contained in these documents is intended for use only by persons having been trained and possessing the requisite skill and know-how and to be used by such persons only at their own discretion and risk.

The nature of these instructions is informative only and does not cover all of the details, variations or combinations in which this equipment may be used, its storage, delivery, installation, check out, safe operation and maintenance.

Since conditions of use of the product are outside of the care, custody and control of Killark, the purchaser should determine the suitability of the product for his intended use and assumes all risk and liability whatsoever in connection therewith.

UL / CSA CONDITIONS OF ACCEPTABILITY

- Open type devices should be mounted through covers / walls of enclosures having adequate strength and thickness in the intended manner. The manufacturer's instructions must be followed.
- The devices have been assessed for use in a service temperature range of -50°C to +60°C.
- With regards to Unclassified Location assessment, gasket temperatures must not exceed 70°C.
- All dead-metal parts shall be grounded or shall contact grounded metal parts in the final assembly.
- The threaded joint located between the auxiliary device body and the end equipment enclosure shall consist of at least six (6) full threads of engagement for M22x1,5 and at least seven (7) full threads of engagement for 3/4" NPSM for Class I locations and 3 full threads of engagement for Class II and III locations.
- These devices were only evaluated relevant to their installation through covers / walls of enclosures with a free volume up to 160 dm³ with a maximum internal explosion pressure of 20 bar (290 psi), all requirements from the relevant standards must be considered in the end application.
- The devices were evaluated for ingress protection when installed in an enclosure wall/cover, and it is known to be Type 4X. When installed on enclosure walls/covers, and the enclosure is also rated Type 4X, it is known to maintain the enclosure ingress protection.
- Metric threads shall have a tolerance Class of 6g/6H or better according to Standard for General Purpose Metric Screw Threads - Tolerances - Part 1, ISO 965-1 and the Standard for General Purpose Metric Screw Threads - Tolerances - Part 3, ISO 965-3.



ATTESTATION OF CONFORMITY

Manufacturer : Killark Electric , Div of Hubbell Inc.(Delaware),
 2112 Fenton Logistics Park Blvd , Fenton, MO 63026, USA
 Tel : (314) 531-0460 | Email: killarkinfo@hubbell.com

Declares in its sole responsibility that the product mentioned below

Product Designation :	Series GZ Actuators, Actuator Assemblies, Pilot Lights, and Potentiometers; Series EXH Circuit Breaker Operators
Type Designation :	Flameproof and Dust Ignition-proof Actuators and Signal Elements

is in conformity with the essential protection requirements of the following Directive(s), Certification Scheme(s) and Standard(s).

Directive(s) / Scheme(s)	Standard(s)
2014/34/EU ATEX Directive	EN 60079-0:2012+A11:2013 EN 60079-1:2014 EN 60079-31:2014
IEC Certification Scheme For Explosive Atmospheres	IEC 60079-0:2011, Ed. 6.0 IEC 60079-1:2014-06, Ed. 7.0 IEC 60079-31:2013, Ed. 2.0
Others	EN 60529:1991+A1:2000+A2:2013

Type Examination Certificate

ATEX	IECEx
SIRA 19ATEX1171U Issue No. 0	IECEx CSA 19.0030U Issue No. 0

Certification Body

ATEX	IECEx
Sira Certification Service (Reg No.: 0518) Unit 6 Hawarden Industrial Park Hawarden, CH5 3US, United Kingdom	Sira Certification Service Unit 6 Hawarden Industrial Park Hawarden, CH5 3US, United Kingdom

Marking: (Note 1)

ATEX	IECEx
II 2G Ex db IIC Gb (up to 35 Liters)	Ex db IIC Gb (up to 35 Liters)
0518 II 2G Ex db IIB+H2 Gb (up to 160 Liters)	Ex db IIB+H2 Gb (up to 160 Liters)
II 2D Ex tb IIIC Db IP66 (Salt Spray)	Ex tb IIIC Db IP66 (Salt Spray)
Tservice= -50°C to +60°C	Tservice = -50°C to +60°C

Note 1: Rating data, characteristics and for incorporation into equipment refer Installation & operating manual.

PQAN compliance has been approved by Notified Body Sira Certification Services Limited (A CSA Group company), Unit 6, Hawarden Industrial Park, Hawarden, Deeside, CH5 3US England (Notified Body 0518).

To verify the status and authenticity of IECEx Certificate of Conformity, please visit [Official IECEx Website](#)

Signature :

Place and Date : Fenton, 2019-08-05

Name : Tom Michalski

Designation : Certifications Manager