


A I3 CONSTRUCTION

REVISIONS

ECL

Transformer Specifications						
PRIMARY VOLTAGE(S)	240×480					
SECONDARY VOLTAGE(S)	24					
RATED V.A.	100					
RATED FREQUENCY	50/60					
INSULATION CLASS	105					
AGENCY APPROVALS	UL,CUL					
ESTIMATED WEIGHT	4.4 LBS					



## NOTES:

- 1. ALL MEASURMENTS IN INCHES (MM)
- 2. TERMINAL SCREWS ARE COMBO #8-32 PHIL-SLOT-1/4" HEX WITH SEMS WASHER.
- 3. SECONDARY FUSE CLIP ACCOMMODATES ONE 13/32" X 1-1/2" MIDGET FUSE.

		1	1 PAIR OF JUMPERS							
			-		ı					
			M	MICRON INDUSTRIES CORPORATION 1211 V.22nd STREET, Suite 200, DAK BRIDK, ILL. 1212 TRANSFORMER 1213 V.22nd STREET, Suite 200, DAK BRIDK, ILL. 1214 V.22nd STREET, Suite 200, DAK BRIDK, ILL. 1215 V.22nd STREET, Suite 200, DAK BRIDK, ILL. 1216 V.22nd STREET, Suite 200, DAK BRIDK, ILL. 1217 V.22nd STREET, Suite 200, DAK BRIDK, ILL. 1218 V.22nd STREET, SUITE						
			DATE	11/5	5/19	DRAWN	JAW	CHECKED	APPROVED	
			RELEASE DATE			CUSTOMER PART NO.	ł			
			MICRON			B100PU7JKA3				
			PART N			B100PU7JKB3				
AN006454	ζ	11/05/19	SIZE	SCALE			$\overline{D10}$	$\overline{\cap \cap \cup \neg}$	11/	
•	BY	DATE		NONE			DΙU	$U \cap U /$	JK.	

PACKAGED ACCESSORIES