



Meter center, MP Meter-Pak, 4 sockets, lever bypass, jaw release, 5 jaws, 600A bus, 225A max breaker rating, ringless

MPL64225

Product availability: Stock - Normally stocked in distribution facility

#### Main

Product	Meter Center
Socket Rating	225 A
Main Type	Main Lugs
Number of Jaws	5
Number of Meter Sockets	4
Socket Type	Ringless

### Complementary

Main Rating	400 A 600 A	
Bus Rating	600 A	
Certifications	UL Listed	
Туре	Meter-Pak	
Busbar Material	Aluminium: busbar	
Bypass Type	Lever bypass	
Enclosure Material	Steel	
Enclosure Rating	NEMA 3R	
Maximum Voltage Rating	120/240 V AC	
Mounting	Surface	
Phase	1 phase	
Service Feed Location	UG OH	
Wire Size	AWG 1/0600 kcmil 1 aluminium AWG 1/0600 kcmil 1 copper	
Wire Configuration	3-wire	
Height	67.37 in (1711.20 mm)	
Width	35.37 in (898.40 mm)	
Depth	9.62 in (244.35 mm)	

### Ordering and shipping details

Category	US10DE400021
Discount Schedule	0DE4

Price is "List Price" and may be subject to a trade discount – check with your local distributor or retailer for actual price.

GTIN	785901336563
Returnability	Yes
Country of origin	MX

# **Packing Units**

Unit Type of Package 1	PCE
Nbr. of units in pkg.	1
Package 1 Height	20.5 in (52.1 cm)
Package 1 Width	42.008 in (106.7 cm)
Package 1 Length	72.008 in (182.9 cm)
Package weight(Lbs)	267.000 lb(US) (121.109 kg)

## **Contractual warranty**

Warranty 18 months



Schneider Electric aims to achieve Net Zero status by 2050 through supply chain partnerships, lower impact materials, and circularity via our ongoing "Use Better, Use Longer, Use Again" campaign to extend product lifetimes and recyclability.

Environmental Data explained >

How we assess product sustainability >

#### **Use Better**


Materials and Substances	
Packaging made with recycled cardboard	No
Packaging without single use plastic	No
EU RoHS Directive	Compliant
REACh Regulation	REACh Declaration
California proposition 65	WARNING: This product can expose you to chemicals including: Lead and lead compounds, which is known to the State of California to cause cancer and birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov

#### Use Again

○ Repack and remanufacture	
Take-back	No

#### **Technical Illustration**


#### **Dimensions**



MPL64225
ALL DIMENSIONS ARE APPROXIMATE.
REPER TO CAID, TECHNICAL DRAWINGS, AND DOCUMENTATION FOR COMPLETE INFORMATION

#### **Technical Illustration**

#### Wiring diagram



#### MPL64225

TENANT SERVICE DISCONNECTS (ORDER ONE PER SOCKET POSITION)				
TENANT CIRCUIT BREAKER (2-POLE)	AMPERE RATINGS MIN MAX.	SHORT CIRCUIT BREAKER RATING RMS SYMMETRICAL AMPERES MAX.	VOLTS MAX.	
QO \$	40 - 125	10,000		
QBP-TM	70 - 225	10,000		
QO-VH ♦	40 - 60	22,000		
QDP-TM	70 - 225	25,000	120/240	
QOH♦	40 - 60	42,000		
QGP-TM	70 - 225	65,000		
QJP-TM	70 - 225	100,000		