

- 5. SUPPLIED WITH (4) SPLICE PLATES, FASTENERS: (16) Ø3/8" X 3/4" LONG SCREWS & (16) Ø3/8" FLANGED HEX NUTS.
- 6. INSTALL IN ACCORDANCE WITH NEMA STANDARD VE-2 "CABLE TRAY INSTALLATION GUIDELINES".
- 7. WARNING! DO NOT USE AS A WALKWAY, LADDER OR SUPPORT FOR PERSONNEL. USE ONLY AS A MECHANICAL SUPPORT FOR CABLES, TUBING, AND RACEWAYS.

1	RELEASED PER DCN211021013702	AD	10/21/21
REV	DESCRIPTION	APP	DATE

LIST OF PARTS

MATERIAL

**ALUMINUM** 

**ALUMINUM** 

STEEL

STEEL

TEE

**FINISH** 

**GEOMET** 

**PLATED** 

**GEOMET** 

**PLATED** 

SEE

CAT. NO. E TABLE

W

M-14448

THE DESIGN AND DIMENSIONS OF THE PRODUCT SHOWN ON THIS DRAWING ARE SUBJECT TO CHANGE WITHOUT NOTICE. DIMENSIONS ARE IN INCHES [mm].

## HORIZONTAL TEE FITTING. LADDER TRAY



WIRING DEVICE-KELLEMS **HUBBELL INCORPORATED** SHELTON, CT

TOLERANCES UNLESS

AD NONE CHK. BY DATE 10/13/21 SBW

CAGE CODE 74545